MALWANCHAL UNIVERSITY

S. NO	BLOCK	FLOOR	UNIT RATING	NO OF BATTERIE	ATING OF BATTERI	POWER FLOW
1	X - Ray	Ground	60 KVA	40	65AH 12V	3 HRS
2	CT Scan	Ground	50 KVA	34	150AH 12V	3 HRS
3	DR - CR	Ground	5 KVA	15	26AH 12V	1 HRS
4	Sonography	Ground	5 KVA	15	42AH 12V	1 HRS
5	Sonography	Ground	3 KVA	Inbuilt	7AH 12V	15 MINT
6	ECHO	Ground	3 KVA	8	26AH 12V	30 MINT
7	Opthal	Basement	5.5 KVA	16	42AH 12V	45 MINT
8	Server	Basement	5 KVA	15	7AH 12V	15 MINT
9	Pathology	Basement	5 KVA	15	65AH 12V	1 HRS
10	Blood Bank	Basement	3 KVA	8	18AH 12V	30 MINT
11	Dailysis	1st Floor	5 KVA	15	7AH 12V	15 MINT
12	IVF	1st Floor	3 KVA	6	18AH 12V	30 MINT
13	IVF	1st Floor	5 KVA	16	7AH 12V	15 MINT

Ghanshyam Vishwakarma
Electrical In charge
Index Medical College,
Nemawar Road, Indore (M.P.)

Registrar
Malwanchal University
Indore (M.P.)

MALWANCHAL UNIVERSITY

S. NO.	Pump Location	Type of Pump	Flow m3/hr	Motor Rating Kw	Hours of use/day
1	Near of D. G. Room	Submersible pump	11400 HRS	7.5 kw	2 HRS
2	Vipin House P.G. Hostel - 1	Submersible pump	11400 HRS	7.5 kw	12 HRS
3	Front of Intern Boys Hostel	Submersible pump	11400 HRS	7.5 kw	12 HRS
4	Vipin House P.G. Hostel - 2	Submersible pump	11400 HRS	7.5 kw	12 HRS
5	MBBS Medical College	Submersible pump	11400 HRS	6.0 kw	6 HRS
6	Back Side of Intern Girls Hostel	Submersible pump	11400 HRS	9.0 kw	14 HRS
7	Front of Dental Boys Hostel	Submersible pump	11400 HRS	7.5 kw	12 HRS
8	Near of Dental Boys Mess	Submersible pump	11400 HRS	9.25 kw	12 HRS
9	Ground Back of Hospital	Submersible pump	11400 HRS	7.5 kw	3 HRS
10	Near of Meera House	Submersible pump	11400 HRS	6.0 kw	6 HRS
11	Near of New Basera	Submersible pump	11400 HRS	7.5 kw	8 HRS
12	Nursing Water Tank NO. 1	Open Well Submersible Pump	51000 HRS	7.5 kw	10 HRS
13	Hospital Water Tank NO. 1	Open Well Submersible Pump	51000 HRS	7.5 kw	12 HRS
14	Hospital Water Tank NO. 2	Open Well Submersible Pump	51000 HRS	7.5 kw	12 HRS
15	Girls Hostel Water Tank	Open Well Submersible Pump	51000 HRS	7.5 kw	14 HRS
16	Girls Hostel Water Tank For Basera	Open Well Submersible Pump	51000 HRS	7.5 kw	12 HRS
17	Nursing Water Tank NO. 2 For Dental Girls	Open Well Submersible Pump	51000 HRS	7.5 kw	10 HRS
18	MBBS Medical College Water Tank	Open Well Submersible Pump	51000 HRS	7.5 kw	4 HRS

Ghanshyam Vishwakarma
Electrical In charge
Index Medical College,
Indore (M.P.)

Malwanchal University
Indore (M.P.)

INDEX MEDICAL COLLEGE

MALWANCHAL UNIVERSITY

S. NO.	LOCATION	NUMBER OF A/C	TON
1	Chairman Office	2	2
2	Dean Office	3	1.5
3	Counselling Hall	3	1.5
4	Admistor Office	1	2
5	Medical Education Unit	2	1.5
6	Biochemistry Department	2	1.5
7	Lecture Hall No. 1	6	2
8	PSM Department	1	1.5
9	Microbiology Department	2	1.5
10	Molecular Biology Lab	8	1.5
11	Pathology Department	2	1.5
12	Central Lab	3	2
13	Lecture Hall No. 2	6	2
14	Physiology Department	1	1.5
15	Pharmacology Department	2	1.5
16	Forensic Medicine Department	1	1.5
17	Lecture Hall No. 3	3	2
18	Auditorium Hall	4	1.5
19	As Profe	1	1.5
20	Centeral Library	3	1.5
21	Faculty Section	1	1.5
22	Reading Room	2	1.5
23	E-Library	2	1.5
24	Ground Floor Library	2	1.5
25	Library Basement New	1	1.5
26	Book Processing Section No. 3	2	1.5

Ghanshyam Vishwakarma
Electrical In charge
Index Medical College,
Nemawar Road, Indore (M.P.)

Registrar
Malwanchal University
Indore (M.P.)